

SA Smoke alarm with internal sounder – linked

HA Heat alarm with internal sounder – linked

FD30 doors

30 Minute fire resistance

SC Self closing device

In lower risk premises of 3 storeys it should be possible to accept substantial solid doors & sound traditional construction

DRAWING NO. 10
3 Storey plus cellar.
Shared house – HMO
January 2009

