

DRAWING NO. 21

3 storey plus basement.
 SC flats to basement, GFI, 1stFl and 2ndFl.
 Bedsit to GFI with bathroom at 1stFl.

January 2009

DS Smoke detector linked to whole house system

DH Heat detector linked to whole house system

⊙ Manual call point linked to whole house system

🔊 Sounder linked to whole house system

IP Control and indicator panel linked to whole house system

🔦 Emergency lighting

SA Smoke alarm with internal sounder – not linked to whole house system

↙ FD30S fire door with self closing device

— 30 minutes fire resistance

EW Escape window

